



NOTES:

1. TRACE WIRE SHALL BE CONTINUOUS #8 COPPER WIRE.
2. THE CONTRACTOR SHALL EXCAVATE BY HAND EXPOSING THE EXISTING PRESSURE SEWER MAIN.
3. THE CONTRACTOR SHALL COAT CONNECTION WITH CORROSION PROTECTION.

WEST BAY	
SANITARY DISTRICT	
FORCEMAIN SERVICE CONNECTION	
APPROVED BY:	
TIMOTHY CLAYTON	4/18/2005
DISTRICT MANAGER	DATE: